Address of property: 49 Redbrink Crescent, Barry, Vale of Glamorgan, CF62 5TU

Fire Risk Assessment completed by Janet Northover, business owner on 29 November 2024

Description of property. The property is a ground floor flat in a late Victorian Terrace. It sleeps two people in one bedroom, with a separate kitchen and sitting area.

Commission and Placement of Appropriate Fire Extinguishers in Properties. There is a fire blanket in the kitchen and two fire extinguishers – one in the hall and one in the kitchen.

Emergency Escape Lighting. Emergency escape lighting is provided, in the form of a plug in torch with lighting. Additional free standing torches are provided in the bedroom. There is a street lamp on the road near the property.

Protected Escape Routes: There are two exit doors, one to the front of the property and one to a rear patio from the bedroom, protected by 30 minute fire doors.

Linked Smoke Detectors: There are interlinked alarms in the bedroom and sitting room. These are mains wired.

Hot Water and Heating Systems: Hot water and heating are provided by a gas boiler, this has a clean gas safety certificate valid until 09 January 2025 carried out by Harry Marshall Gas Safe Engineer number 913941. Gas Safe Certificate number 45c 29

Thumb Turn Locks: Keyless exits are provided from the flat to the hallway and from the hallway through the front door. Additionally there is a keyless exit from the patio door to the rear courtyard.

EICR (Fixed Wiring Check. An EICR was issued on 7/4/21 with no advisories, carried out by R and M Electrical, certificate number 23142223

Regular Safety Checks: Fire equipment is checked at each change of occupancy. We rarely let for more than 7 days, if we do, a date for checking during longer stays will be agreed in advance with the guests. The fire equipment checks are recorded and the records held off site.

Candle Policy. Guests are provided with a policy banning the use of candles, melts or any other naked flame.